

## SANDELL'S CKD (COPPER KRAFT DUPLEX)

### DESCRIPTION

A full sheet of 2, 3, 5 or 7oz. copper bonded on both sides by asphalt, to a heavy waterproof creped Kraft paper.

### CHARACTERISTICS

A permanent, economical laminated thru-wall flashing consisting of five (5) layers of time proven waterproofing materials combined under heat and pressure into a single sheet. It is flexible and is easily formed by hand at the jobsite.

### Features include:

1. Copper to withstand all harmful acid and alkali action that is present in fresh mortar. Copper is permanently waterproof, high in tensile strength to resist stretching and tough enough to bear the compressive forces in the masonry wall without harmful cold flow.
2. Tough coating of asphalt on both surfaces of the copper core, providing additional waterproofing and chemical resistance.
3. Covering of heavy waterproofed creped kraft paper on both sides to reinforce the entire assemblage, protect the copper from damage. In handling during installation and to provide a rough textured surface which promotes an excellent bond in the mortar joint.
4. Asphalt properly applied in the manufacturing process provides a perfect adhesive between copper and Kraft paper.

### MODEL SPECIFICATIONS

#### Special Requirements:

All materials specified will be delivered to the site in approved manufacturer's sealed containers bearing manufacturer's name and material identification.

#### Preparation:

All masonry surfaces receiving thru-wall flashing will be thoroughly dry, free from loose material, and reasonably smooth. There will be no slopes that will form pockets or prevent free drainage of water to the exterior surfaces of the wall. All work will be executed in conformance with accepted trade practice.

### Materials:

Flashing will be Sandell Copper Kraft Duplex consisting of a full sheet of copper weighing (specify 1, 2, 3, 5 and 7oz. copper) per sq. ft. bonded on both sides by asphalt to heavy, waterproofed creped Kraft paper. (3, 5, and 7oz. are reinforced with heavy interlacing fibers.)

### APPLICATIONS

**Horizontal Masonry Surfaces:** Flashing will be laid in a slurry of fresh mortar and topped with a fresh full bed of mortar. Flashing will be carried through the wall as detailed and left exposed at the exterior for inspections only. After inspection, flashing will be cut flush with the exterior masonry.

#### Vertical Masonry Surfaces:

Surfaces receiving the flashing will be sufficiently spotted with Sandell Asphalt Trowel Mastic to hold it in place until masonry is set. Secure in back wall mortar joint or reglet as detailed.

#### Foundation Sill Flashing:

The flashing for foundation sills will be laid in a slurry of fresh mortar and topped with a fresh full bed of mortar. Flashing will be left flush with exterior face of the masonry and turned up on the inside not less than 2" or be carried upward across the cavity a minimum of 6". Flashing will then be secured in the back wall in a reglet or mortar joint. Where sill and column meet, flashing will be brought a minimum of 10" up the column and be secured with Sandell Asphalt Trowel Mastic.

#### Cavity Wall Flashing:

Flashing will be laid in a slurry of fresh mortar and topped with a fresh full slurry of mortar. Flashing will be left flush with the exterior face of the masonry wall and carried through the wall, upward across the cavity a minimum of 6", and be secured in the back wall mortar joint or reglet.

#### Spandrel Flashing:

Spandrel flashing will start from the outside toe of the shelf angle, go up the face of the beam and then through the wall turning up on the inside not less than 2".



# TECHNICAL DATA SHEET

**Parapets or Copings:**

Flashing for parapets or copings will be laid in a slurry of fresh mortar and topped with a fresh full bed of mortar. Flashing will come flush with the exterior and interior faces of the masonry wall.

*Head and Sill Flashing:*

The flashing will start flush with outside of the wall or lintel angle, then carried through or up the wall as indicated. Flashing will extend 6" beyond each side of the opening and be turned up at the sides forming a pan. All corners will be folded, not cut.

*Other Locations:*

All membrane flashing at other locations will be installed in accordance with manufacturer's recommendations.

*Joining of Materials:*

Joint will be made by lapping a minimum of 4" and coating the contacting surfaces with Sandell Asphalt Trowel Mastic.

**Weep Holes:**

All flashing installed through masonry will be provided with proper drainage to outside. Weep holes will be provided in the

head joint, the first course immediately above the flashing. Weep holes will be kept free of mortar droppings.

**INSPECTION**

In each area where membrane flashing has been installed, a minimum of three locations in the wall joint above the flashing will be left clean of mortar for water to be forced into the opening to determine if flashing has been installed properly and weep holes provided in accordance with these specifications. All flashing that has been left exposed to the

exterior should be trimmed flush with the exterior masonry at this time.

**TECHNICAL ASSISTANCE:**

Call Sandell directly for technical assistance or product questions:

New York: 800.283.3888

Alabama: 877.726-3355

Wisconsin: 800.323-3565



[www.sandellmfg.com](http://www.sandellmfg.com)

**Amendments / Notes:**


Sandell Employee:

Date:

CORPORATE OFFICE  
NEW YORK  
Toll Free: 800-283-3888  
Fax: 518-357-9757

BRANCH OFFICE  
ALABAMA  
Toll Free: 877-SANDELL  
Fax: 205-263-1033

BRANCH OFFICE  
WISCONSIN  
Toll Free: 800-323-3565  
Fax: 414-764-6993